

Fixed Ladders Checklist

This checklist does not address fixed ladders with cages, baskets, wells, hatch covers, landing platforms, or ladders exceeding 20 feet in height (see 29 CFR 1910.27). It also does not address fixed ladders associated with construction sites (see 29 CFR 1926.1051 and 1926.1053). Consult the OSHA regulations for requirements in these situations.

General Inspection	Yes	No	OSHA Reg.
1. Is the distance between rungs 12 inches or less and uniform throughout the length of the ladder?			29 CFR 1910.27(b)(1)(ii)
2. Is the minimum clear length of rungs or cleats at least 16 inches?			29 CFR 1910.27(b)(1)(iii)
3. Are the rungs, cleats, and steps free of splinters, sharp edges, burrs, or other projections that are hazards?			29 CFR 1910.27(b)(1)(iv)
4. Are the rungs of ladders designed so that the foot cannot slip off the end?			29 CFR 1910.27(b)(1)(v)
5. Are the rungs of metal ladders at least three-fourths ($\frac{3}{4}$) of one (1) inch in diameter? (Note: If the ladder is embedded in concrete and serves as an access to pits or other atmospheres that cause corrosion and rusting, the rungs must be at least one inch in diameter or be painted or treated to resist corrosion and rusting.)			29 CFR 1910.27(b)(1)(i)
6. Are the rungs of wood ladders at least one and one-eighth ($1\frac{1}{8}$) inches in diameter?			29 CFR 1910.27(b)(1)(i)
7. Do side rails that might be used as a climbing aid provide adequate gripping surface without sharp edges, splinters, or burrs?			29 CFR 1910.27(b)(2)
8. Are metal ladders painted or treated to protect them from corrosion and rusting when location demands?			29 CFR 1910.27(b)(7)(i)
9. Are wood ladders treated with a nonirritating preservative when used under conditions that may cause decay?			29 CFR 1910.27(b)(7)(ii)
10. Is the perpendicular distance from the center line of the rungs to the nearest permanent object on the climbing side of the ladder 36 inches for a pitch of 76 degrees and 30 inches for a pitch of 90 degrees? (Note: The intent of this provision is to prevent the climber from bumping his or her head or shoulder on an object while climbing or descending the ladder.)			29 CFR 1910.27(c)(1)
11. Is the distance from the center line of the rung, cleat, or step to the nearest permanent object behind the ladder at least seven (7) inches? (Note: The purpose of this provision is to give adequate clearance so that the climber's foot does not strike an object between the wall and the ladder and cause a fall.)			29 CFR 1910.27(c)(4)

<p>12. Is the distance from the center line of the grab bar to the nearest permanent object behind the grab bar at least four (4) inches? (Note: The purpose of this provision is to ensure that the climber can grab the bar quickly and easily.)</p>			<p>29 CFR 1910.27(c)(5)</p>
<p>13. Is the step-across distance from the nearest edge of the ladder to the nearest edge of the equipment or structure not more than 12 inches and not less than two and one half (2½) inches? (Note: If the step-across distance is greater than 12 inches, a landing platform of at least 24 inches wide and 30 inches long must be provided with standard railings and toe boards. Consult the OSHA regulations 29 CFR 1910.27(d)(2)(ii) for requirements.)</p>			<p>29 CFR 1910.27(c)(6)</p>
<p>14. Are the side rails of ladders extended at least three and one half (3½) feet above the landing? (Note: The purpose of this standard is to give the climber something to hold on to while getting off and on the ladder.)</p>			<p>29 CFR 1910.27(d)(3)</p>
<p>15. Are all ladders inspected regularly and maintained in a safe condition?</p>			<p>29 CFR 1910.27(f)</p>

Date of Inspection: _____

Location of Inspection: _____

Signature of Inspector: _____

Source:

Centers for Disease Control and Prevention. NIOSH. Fixed Ladders Self-Inspection Checklist. (2014, June 6). Retrieved from <http://www.cdc.gov/niosh/docs/2004-101/chklists/r1n18f~1.htm>

KEMI does not assume liability for the content of information contained herein. Safety and health remain your responsibility. This information is to be used for informational purposes only and not intended to be exhaustive or a substitute for proper training, supervision or manufacturers' instructions/recommendations. KEMI, by publication of this information, does not assume liability for damage or injury arising from reliance upon it. Compliance with this information is not a guarantee or warranty that you will be in conformity with any laws or regulations nor does it ensure the absolute safety of any person, place or object, including, but not limited to, you, your occupation, employees, customers or place of business.